

24ITB005 Behavioral Health Clinic Remodel

Addendum #1 Questions and Answers

Issued: 11/07/2023

1 of 1

Question Number	Date Received	Question	Answer
Q1-1	10/31/2023 1:15 PM	On A100 there is a window notated 'A' from Waiting Room 100 to Manager 109, is this going to be a 1-way mirror? Please advise.	<i>No. The referenced window should be a standard tempered glass window.</i>
Q1-2	10/31/2023 1:15 PM	Is GC going to be responsible for Door or Room Signage?	<i>No. The Health District will be responsible for door and room signage.</i>