

## Aquatic Health Program Agenda

<b>Subject</b>	<b>AHP Ops 2026 February Industry Meeting</b>	<b>Date</b>	<b>February 24, 2026</b>
<b>Facilitator</b>	<b>Alicia Mitchell and Candice Stirling - EH Supervisors</b>	<b>Start</b>	<b>2:30 pm</b>
<b>Location</b>	<b>Red Rock Conference Room/Teams</b>	<b>End</b>	<b>4:00 pm</b>
<b>Attendees</b>			
<b>No</b>			
1	<b>Open Meeting</b>	<ul style="list-style-type: none"> <li>• Welcome</li> <li>• Staff Introductions</li> </ul>	
2	<b>Staff Presentations</b>	<ul style="list-style-type: none"> <li>• Pool fence height requirements</li> <li>• Operational considerations for designing new pools and pool areas</li> <li>• Cold plunges</li> <li>• Property management changes and invoicing</li> <li>• New EH software coming (Accela)</li> </ul>	
3	<b>Questions &amp; Answers</b>	<ul style="list-style-type: none"> <li>• Questions?</li> </ul>	

PLAN			
No.	Action Item(s)	Owner	Target Date

Approved by: \_\_\_\_\_ Date: \_\_\_\_\_

### **2-604 Enclosures and Barriers**

**2-604.1** The ENCLOSURE may consist of any combination of building envelopes, site walls, or fencing as provided for in this Section.

**(A)** ENCLOSURES shall be provided between CHEMICAL STORAGE SPACES, AQUATIC VENUE, mechanical spaces, and areas accessible to the public, in accordance with local building codes.

#### **2-604.2 Construction Requirements**

**(A)** ENCLOSURES for AQUATIC VENUES shall not block or encumber a required emergency egress path from other structures.

**(B)** Windows on a building that form part of an ENCLOSURE around an AQUATIC VENUE shall have a maximum opening width not to exceed four (4) inches.

**(C)** Living or lodging units shall not enter directly into a common AQUATIC VENUE ENCLOSURE.

**(D)** For the purposes of this Section, height shall be measured from finished grade to the top of the ENCLOSURE on the side outside of the ENCLOSURE surrounding an AQUATIC VENUE.

**(1)** Where a change in grade occurs at an ENCLOSURE, height shall be measured from the uppermost grade to the top of the ENCLOSURE.

**(2)** AQUATIC FACILITY ENCLOSURES shall not be less than six (6) feet in height for all new construction, SUBSTANTIAL ALTERATION, or any ENCLOSURE alterations.

**(3)** Any vertical members in the ENCLOSURE must not be more than four (4) inches apart. Any opening at the bottom of the ENCLOSURE must not be more than four (4) inches in height. Mesh style fencing must not exceed 1 3/4 inch openings.

**(4)** The ENCLOSURE must be installed above a fixed, permanently installed solid surface.

**(5)** Except where otherwise noted, all other BARRIERS not serving as part of an AQUATIC FACILITY ENCLOSURE shall not be less than 42 inches in height.

#### **2-604.3 Gates and Doors**

**(A)** Egress from a publicly accessible space within a building shall not open directly into the ENCLOSURE of the AQUATIC VENUE.

**(B)** All primary public access gates or doors serving as part of an AQUATIC FACILITY ENCLOSURE or required AQUATIC VENUE ENCLOSURE must be self-closing and self-latching from any open position.

**(C)** All gates or doors shall be capable of being locked from the exterior. Electronically locked gates must be equipped with a back up battery to maintain function when power is interrupted.

**(D)** Gates or doors shall be designed in such a way that they do not prevent egress in the event of an emergency.

**(E)** Gates shall be at least equal in height at top and bottom to the ENCLOSURE of which they are a component.

## Aquatic Health Program Agenda

- (F)** Unattended turnstiles shall not form a part of an AQUATIC FACILITY ENCLOSURE.
- (G)** EXIT GATES shall swing away from the AQUATIC VENUE ENCLOSURE except where emergency egress codes require them to swing into the AQUATIC VENUE ENCLOSURE.
- (H)** Self-latching mechanisms:
  - (1)** Must be located not less than 3 1/2 feet above finished grade and
  - (2)** Shall not be operable by small children on the outside of the ENCLOSURE around the AQUATIC VENUE.
- (I)** For all other AQUATIC VENUES, EXIT GATES or doors shall be constructed so as to prevent unauthorized entry from outside of the ENCLOSURE around the AQUATIC VENUE.
- (J)** In lieu of meeting the requirements of Section 2-604, AQUATIC FACILITIES with 24-hour security by one or more persons with a physical presence at all AQUATIC VENUES within an ENCLOSURE may apply for a WAIVER to this Section.

### **2-604.4 INDOOR AQUATIC VENUES**

- (A)** Building walls enclosing an INDOOR AQUATIC FACILITY may be designated as the AQUATIC FACILITY ENCLOSURE.
- (B)** INDOOR AQUATIC VENUES shall be securable from unauthorized entry from other building areas and the exterior.
- (C)** Where separate indoor and outdoor AQUATIC VENUES are located on the same site, an AQUATIC VENUE ENCLOSURE shall be provided between them.

**Exception:** Where all AQUATIC VENUES are operated continuously 12 months a year on the same schedule.

### **2-604.5 Except as otherwise required in these Regulations, one ENCLOSURE may surround multiple AQUATIC VENUES at one facility.**

- (A)** WADING POOLS and CHILD AMUSEMENT LAGOONS shall not require separation from other WADING POOLS and CHILD AMUSEMENT LAGOONS by a BARRIER. Refer to Section 2-1008 for additional guidance about WADING POOLS.