



PLAN REVIEW MINIMUM REQUIREMENTS

PRIOR TO A FINAL PERMITTING INSPECTION, THE PERSON IN CHARGE SHALL VERIFY:

- Hand sink(s) with Hot & Cold running water
- Restroom(s) operable
- Utility sink (exception of Child Care)
- Sewage disposal (floor sinks, drains, interceptor)
- Backflow protection
- Lighting & Equipment
- Approved Materials/Finishes & Outer Openings protected
- All utilities are operable
- As-built plans submitted to SNHD to include any updates
- Approvals from agencies as required
Examples: TCO/CO, Building Approval, Fire Approval, AMMR/Waiver
- Is construction done? Are you ready for customers?

IN ADDITION, FOR EACH PERMIT TYPE VERIFY:

Food Facilities

- Additional Plumbing Requirements:
 - 3-compartment sink
 - Glass washer for satellite bars
 - Dump/Prep sinks as needed
- Menu (All open food/beverage facilities)
- Adequate Hot/Cold holding and dry storage
- Ventilation hood over cooking equipment
- Grease interceptor in open food facilities
- PIC Knowledge and Food Handler Cards

Schools

- Restrooms within 250ft of classrooms
- Pre-K Toilet and Hand Sink Height
- Toilet and Hand Sink Ratios met
- Drinking Fountain/Water Provided
- Health Office
- Temperature of Rooms (65-85F)

Body Art

- 100 sq ft per station/booth
- Permanently plumbed hand sink at each body artist workstation
- Written Consent, After Care, Infection Control Plan
- Staff: Health Card, Bloodborne Pathogens, CPR & First Aid

Food Trucks/Trailers

In addition to what is required for Food Facilities, Trucks and Trailers must have:

- Fire Suppression Inspection Tag showing recent inspection and approval.
- Gas Line Inspection Report showing recent inspection and approval.
- Is the operation easily conveyable to the commissary?

Child Care

- Hand Sink & Toilet Ratio 1:15 (New/Maj)
- Diapering Area (30" min height) w/Hand Sink
- Toilet (11" 3-5yo & 15" Kinder)
- Hand sink height (21"-26" range)
- Dump/Rinse Sink in Nursery for bottles
- Classroom Temperature (65-82F)
- Isolation Area
- Restroom-5ft impervious finish
- Drinking water available for activity areas
- Menu (if foodservice is provided)

**THIS LIST IS NOT ALL INCLUSIVE
FOR ADDITIONAL REGULATORY REQUIREMENTS,
VISIT WWW.SNHD.INFO/PLAN-REVIEW**