LEGIONELLA INVESTIGATION REPORT

Facility Information			
Facility Name:	ABC Company	**Date of Initial Site Visit:**	1/1/2024
Address:	123 Main St. City, State ZIP	**EHS:**	1234

Sampling Efforts

Water Samples were taken from case room, distal room, hot water return, and front entry fountain.

Samples were taken to a local ELITE certified laboratory. Three sample(s) detected positive for *Legionella* bacteria during the initial site visit.

Remediation Efforts

Remediation on the affected water riser was completed on **[DATE].**

The facility began the post-remediation sampling schedule on **[DATE].** All samples were non-detect for the bacteria during the sampling schedule.

Post-remediation sampling was completed on **[DATE].** All samples were non-detect for *Legionella* bacteria.

SNHD requested facility test 1% of the guest rooms at the other water risers of the facility. All samples were negative for *Legionella* bacteria.

Conclusion

The EH investigation was completed on **[DATE].**

P.O. Box 3902 | Las Vegas, NV 89127
702.759.1000 | www.SouthernNevadaHealthDistrict.org